

Town of Portland
Addendum #2 Bid #2022-01

BID #2022-01 BROWNSTONE AVENUE REMEDIATION PROJECT

Date Issued September 10, 2021

ALL BIDDERS ARE HEREBY ADVISED OF THE FOLLOING INFORMATION AND/OR MODIFICATIONS TO THE CONTRACT BID DOCUMENTS:

- **The Bid due date has been extended until Tuesday September 21, 2021 at 3:00 P.M.**
- **The Remedial Action Plan for the project prepared by Tighe & Bond has been posted on the Town Website <https://www.portlandct.org/bids-frps-frqs> for informational purposes.**
- **The Sign-In sheet from the mandatory pre-bid meeting is being provided.**

Contractor Questions submitted in writing by September 8, 2021 were as follows:

Question: Line Item 14 on the bid form calls for excavation and off-site disposal of PCB containing soil (100 cubic yards). Typically, disposal is measured per ton as it is weighed at the disposal facility.

Answer: We provided measurement in cubic yards since excavation can't be measured in tons. The weight in tons is calculated for disposal by multiplying the CY by a factor of 1.5 or 2 (depending upon soil type).

Question: Article 8.20 of the bid documents(page 0200-6) states that a Bid Bond form is provided in the specifications, it is not. May we use a standard AIA-A310 Bid bond instead?

Answer: Refer to Addendum # 1 for the appropriate bid bond form. The standard AIA-A310 Bid bond should not be used.

Tom E. Robinson, CPA
Director of Finance
Town of Portland, CT